



PRI Evaluation Report

PRI ER 1378E12

Issue Date: 12/17/2024

Last Revision: Original Issue

This Report is Reviewed Annually

Visit: pri-group.com for current status.

Report Holder: **TAMKO Building Products LLC**
 220 W. 4th Street
 Joplin, MO 64801
 (800) 641-4691
tamko.com

SCOPE

Subject: Synthetic Roof Underlayment

Manufacturing Location:

Products:

TAMKO Synthetic Guard™ Underlayment
 TAMKO Synthetic Guard™ Plus Underlayment

<u>Factory ID</u>	<u>Location</u>
Silvassa, India	Khanvel Rd, Dapada Dadra & Nagar Haveli-396230, India

CSI MasterFormat® :

DIVISION: 07 00 00 – THERMAL AND MOISTURE PROTECTION
 Sub-level 2: 07 30 00 – Steep Slope Roofing

Code References:

- 2024 International Building Code® (IBC)
- 2024 International Residential Code® (IRC)

Properties Evaluated:

- External Fire Exposure (ASTM E108)
- Physical Properties (ASTM D8257)

Evidence Submitted:

- Recognized test report(s) indicating compliance with ASTM E108
- Recognized test report(s) indicating compliance with ASTM D8257
- Quality Documentation
- Manufacturer’s Drawings and Installation Instructions



PRODUCT DESCRIPTIONS and USE

Product Descriptions:

TAMKO Synthetic Guard™ Underlayment is a mechanically attached multi-layered, polymer-coated roofing underlayment with a woven reinforcement. The product is black on the exposed side and supplied in 10 sq. rolls.

TAMKO Synthetic Guard™ Plus Underlayment is a mechanically attached multi-layered, polymer-coated roofing underlayment with a woven reinforcement. The product is black on the exposed side and supplied in 10 sq. rolls.

Product:	Factory IDs:	Dimensions:
TAMKO Synthetic Guard™ Underlayment	Silvassa, India	Length: 286 ft Width: 42 in Weight: 1.9 lb/100ft ²
TAMKO Synthetic Guard™ Plus Underlayment	Silvassa, India	Length: 286 ft Width: 42 in Weight: 2.35 lb/100ft ²

Uses:

The roofing underlayments covered under this report are polymeric sheet material used in steep slope roofing. They are recognized as ASTM D8257 roof underlayments as specified in the following codes:

- 2024 IBC Chapter 15
- 2024 IRC Chapter 9

Underlayments may be used as a component in fire classified roof assemblies when installed as described in the report and in accordance with the following codes:

- 2024 IBC Section 1505
- 2024 IRC Section R902

Fire Classification:

The underlayment covered under this report may be used as a component in approved, fire classified roof covering systems. When installed directly on minimum 3/8 inch thick exterior plywood decking (DOC PS-1) underlayments are part of a fire classified roof assembly in accordance with ASTM E108 and qualify for use under the following codes and when used with the allowable roof covers indicated in the following table:

- 2024 IBC Section 1505.1
- 2024 IRC Section R902.1

Product:	Fire Classification:	Allowable Roof Coverings:
TAMKO Synthetic Guard™ Underlayment	Class A Unlimited slope	ASTM D3462 asphalt shingles
TAMKO Synthetic Guard™ Plus Underlayment	Class A Unlimited slope	ASTM D3462 asphalt shingles



INSTALLATION – GENERAL

Underlayments covered under this report shall be installed in accordance with the applicable code, this report, and the manufacturer's published installation instructions, which shall be available at all times on the jobsite during installation. The underlayments are not the primary roof cover and as such are not intended to be left permanently exposed to direct weather.

Underlayments covered under this report have been evaluated for application to wood decks installed over ventilated attic spaces. Application to other surfaces is outside the scope of this evaluation.

Roof slopes shall be minimum 2:12 (16.67% slope or 9°). The underlayment has an orientation and shall be laid with the topside (i.e. print side) up. The underlayment shall be laid horizontally (i.e. parallel to the eave) starting at the lower edge of the roof. The underlayment shall be mechanically attached to structural wood deck in accordance with the local building codes. If the roof will not be covered immediately (i.e. same day), underlayment shall be independently attached to structural wood deck using fasteners.

Underlayments covered under this report are intended for exterior applications only. Roof coverings shall be mechanically fastened through to the wood deck. Roof coverings shall not be adhered to the underlayment.

Deck:

Deck surface shall be clean, smooth, dry, free of debris, and structurally sound prior to installing underlayment. All deck fasteners shall be checked for protrusion and corrected prior

to underlayment application. Replace any damaged or rotted deck.

Fasteners:

Fasteners shall be ring or deformed shank nails with 1 inch diameter metal or plastic caps. Metal caps shall have a minimum thickness of 32 gauge (0.0134 inch) sheet metal for loose caps or 0.010 inch for power driven cap nails. Plastic caps shall have an outside edge minimum thickness of 0.035 inch. Nail shank shall be minimum No. 14 gauge (0.083 inch shank diameter) galvanized or stainless steel corrosion-resistance nails. Fasteners shall penetrate into the deck minimum $\frac{3}{4}$ inch, or through the deck, where the deck is less than $\frac{3}{4}$ inch thick. Dimensional tolerances of fasteners shall conform to ASTM F1667.

TAMKO Synthetic Guard™ Underlayment and TAMKO Synthetic Guard™ Plus Underlayment are permitted to be installed with staples when the primary roof covering is installed on the same day as the underlayment and in accordance with the manufacturer's installation instructions.

Reroofing:

Prior to the reroofing, all existing roofing shall be removed down to the deck. Exposed deck surface shall be clean, smooth, dry, free of debris, and structurally sound prior to installing underlayment. All deck fasteners shall be checked for protrusion and corrected prior to underlayment application. Replace any damaged or rotted deck.



CONDITIONS OF USE & IDENTIFICATION

The products described in this report comply with, or are suitable alternatives to, the codes listed in this report, subject to the following conditions:

- The products as well as the installation methods shall be in compliance with the applicable code, this report, and the installation instructions provided by the manufacturer. If the manufacturer's installation instructions differ from what is listed in this report, this report governs.
- This report does not supersede the local jurisdiction regulations and the final approval of the building products, materials, or systems in this report is the responsibility of the authorities having jurisdiction.
- This report is only valid if the product(s) and/or the referenced documentation/codes related to the products do not change. If there is a change in product(s) and/or the referenced documentation/codes related to the products, PRI Construction Materials Technologies, LLC shall be informed and further action may be necessary to revalidate this report.
- This report, in its entirety, shall be available at job sites upon request by the user or for inspection by the Building Official. A copy of this report in full shall be provided by the manufacturer or its distributors.
- The products are identified by marks bearing the report holder's name, the manufacture location, the product name, and the Seal of the PRI Validation Program for Building Materials. The Seal shall indicate, at a minimum, the following:
 - a. ASTM D8257
 - b. ASTM E108, Class A under ASTM D3462 Asphalt Shingles
- The products are manufactured at the locations listed in this report and are manufactured under a quality control program with inspections and/or surveillance by PRI Construction Materials Technologies, LLC.
- This report is a supplement to product certification. The products listed herein shall be certified separately under the PRI Validation Program for Building Products. This report alone is not a product certification and requires separate product certification under the PRI Validation Program for Building Products to be valid.
- The current status of this report as well as a directory of certified products, including supplemental PRI Evaluation Reports, can be found at pri-group.com.

© 2024 PRI Construction Materials Technologies, LLC

This PRI Evaluation Report is for the exclusive use by the Client with which a signed agreement was made with PRI Construction Materials Technologies, LLC. PRI Construction Materials Technologies, LLC is only responsible and/or liable for the terms and conditions outlined in that signed agreement. Only the Client has authority to distribute or authorize distribution of the report in its entirety and they shall not do so in a misleading manner. Any loss, expense, or damage caused by the use of this report to any party, other than the Client in accordance with the agreement, is not the responsibility or fault of PRI Construction Materials Technologies, LLC. PRI Construction Materials Technologies, LLC has no financial interest, nor does it have intent to acquire financial interest, in the manufacture or the distribution of the product(s) listed in this report. PRI Construction Materials Technologies, LLC is not under the ownership, operation, or control of the manufacturer or the distributor of the product(s) listed in this report. PRI Construction Materials Technologies, LLC does not guarantee any representations or warranties on any product(s) or subjects contained in this report. This PRI Evaluation Report is an evaluation of building code and is in no way an endorsement or a recommendation for use for the product(s) listed within. All data utilized in support of this report comes from accredited laboratories that show compliance with ISO/IEC Standard 17025 by the International Accreditation Service (IAS) or by any other accreditation body that is a signatory to the International Laboratory Accreditation Cooperation (ILAC) Mutual Recognition Arrangement (MRA). The accuracy of any data that comes from an accredited laboratory that is not PRI Construction Materials Technologies, LLC is the responsibility of the publishing laboratory alone; PRI Construction Materials Technologies, LLC does not accept any responsibility for the accuracy of this data.